



Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER	VAMP Ltd Yrittajankatu 15 FIN-65381 Vaasa Finland
PLACE OF PRODUCTION	Virtaviiva 9 VAASA FI-65100 Finland
DESCRIPTION	Feeder / Motor Protection Relay
TYPE	VAMP40
APPLICATION	Marine, offshore and industrial use in environmental categories ENV1, ENV2 ⁽¹⁾ and ENV3 as described in Lloyd's Register Test Specification No. 1: 2002 (1) <i>Additional anti-condensation heaters must be switched on at all times.</i>
SPECIFIED STANDARDS	IEC 60255
RATINGS	Refer to manufacturer's specification

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. 07/00016 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No.	07/00016
Issue Date	18 March 2007
Expiry Date	17 March 2012
Sheet	1 of 1

M.H.A. Rufaie
London Design Support Services
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.